



## Second Round of Water testing results.

For lead, the threshold is 15 parts per billion. For copper, the threshold is 1,300 part per billion.

Our results show the following.

<u>Location</u>	<u>Lead</u>	<u>Copper</u>
Main Kitchen	NOT DETECTED*	210
2 <sup>nd</sup> floor original building	NOT DETECTED*	310
2 <sup>nd</sup> floor 99 addition	NOT DETECTED*	320
2 <sup>nd</sup> floor 07 addition	NOT DETECTED*	320
Admin Kitchen	NOT DETECTED*	280

NOT DETECTED\* = less than 1ppb.